



THIS WIRE NOT REQUIRED FOR THIS APPLICATION

TERMINAL BLOCK CONNECTIONS SHOWN ARE CONFIGURED FOR 120-240V 60HZ REFER TO FOR OTHER AC WIRING

6-POS TERMINAL BLOCK

REMOVE JUMPER FOR FIRE SUPPRESSION SYSTEM CONNECTION (SEE NOTE 1)

FOR WESTERLINK UNIT CONNECT 1 AMP FUSE (+18 RED) WIRE TO S2

NOTE:
1. FIRE SUPPRESSION SYSTEM CONNECTION IS NOT A POWER SOURCE. THIS CIRCUIT MUST BE CLOSED TO RUN. OPEN TO STOP GENSET.

TOLERANCES (UNLESS OTHERWISE NOTED)		WESTERBEKE CORPORATION TAUNTON, MA. 02780	
INCHES	MILLIMETERS	TITLE	DWGSET WIRE 20.0 EDR
.XX	.02	DATE	27Apr/09
.XXX	.005	SCALE	NONE
CASST	.XX ± .13	SIZE	DRAWING NUMBER
ANGLES	30°	REV.	1
FINISH	3X	MATERIAL:	
DIMENSIONS		DRAWN BY	
INCHES		DATE	
MILLIMETERS		SCALE	
(WHEN APPLICABLE)		SHT. 1 of 1	
		E 54519	