



ALTERNATOR, 40A-24VDC




WATER TEMPERATURE SWITCH

WATER TEMPERATURE SENDER


ALTERNATOR, 50A-12VDC



AIR INTAKE HEATER




PREHEAT SOLENOID




SEE NOTE 2


20A CIRCUIT BREAKER-12VDC



10A CIRCUIT BREAKER-24 VDC



EXHAUST TEMPERATURE SWITCH



OIL PRESSURE SWITCH




OIL PRESSURE SENDER



FUEL SOLENOID




BATTERY SWITCH



12-24 VDC

STARTER MOTOR




GOVERNOR CONTROL

OVERSPEED BOARD


TRANSIENT VOLTAGE SUPPRESSOR



TB3



TB2



TB1




TB1-1




TB1-2




TB1-3



TB1-4




TB1-5



TB1-10




TB2-1





NOTE:

1. REMOVE JUMPER WHEN CONNECTING A SECOND REMOTE PANEL.
2. GROUND "1" TERMINAL OF PREHEAT SOLENOID ON 24V SYSTEM ONLY.



INSTRUMENT PANEL



NOTE:  
O REMOTE CONNECTOR PINS

-TYPICAL REMOTE START/STOP PANEL CONNECTIONS-

TOLERANCES (UNLESS OTHERWISE NOTED)		WESTERBEKE CORPORATION AVON MA. 02322	
INCHES	MILLIMETERS	TITLE	DATE
.XX	.005	WIRING DIAGRAM/SCHEMATIC,	16/Mar/00
.XX	.005	32.0 BEDA - SRC	
CAD	.02	DRAWN BY	DATE
FINISH	.2	APPROVED BY	DATE
		MATERIAL	
DIMENSIONS		SCALE NONE	
INCHES		SIZE DRAWING NUMBER	
(WHEN APPLICABLE)		SHT. 1 of 1	
E		44737	

5536	5/25	B	ADDED OVERSPEED BOARD	GA
4664	8/7	A	ADDED TRANSIENT VOLTAGE SUPPRESSOR TO CIRCUIT	TSM
ECO NO.	DATE	REV.	REVISION RECORD	AUTH. DR. BY