

ECO NO.
DATE
REV.
REVISION RECORD
AUTH.
DR.BY
#10 ORN
ALTERNATOR, 24V, 42A
WATER TEMPERATURE SENDER
WATER TEMPERATURE SWITCH
GLOW PLUGS
#12 RED
PREHEAT SOLENOID
#14 BRN
#14 RED/PUR
FUEL SOLENOID
OIL PRESSURE SWITCH
OIL PRESSURE SENDER
#14 PUR/WHT
GROUND TO ENGINE BLOCK
EXHAUST TEMPERATURE SWITCH
20A CIRCUIT BREAKER
BATTERY SWITCH
24 VDC
#12 YEL/RED
STARTER MOTOR
#14 RED
#14 TAN
#14 BLU
#14 BRN
#14 PUR/WHT
FUEL PUMP
EMERGENCY STOP SWITCH
TB2
TB1
REMOVE THIS JUMPER WHEN CONNECTING A REMOTE PANEL.
#12 YEL/RED
FIRE ALARM N.C. CONTACTS
#10 RED/WHT
#14 YEL
#14 ORN
#14 PUR
#10 RED
#14 WHT
#14 GRN
OIL PRESSURE
WATER TEMP
HOUR METER
VOLT METER
START SWITCH
PREHEAT SWITCH
STOP SWITCH
INSTRUMENT PANEL
24 VDC
BATTERY SWITCH
STARTER SOLENOID
STARTER
PREHEAT SOLENOID
GLOWPLUGS
ALTERNATOR
TB2-3
20 AMP CIRCUIT BREAKER
START SWITCH
EMERGENCY STOP SWITCH
PREHEAT SWITCH
STOP SWITCH
FUEL PUMP
FUEL SOLENOID
EXHAUST TEMP. SWITCH
WATER TEMP. SWITCH
OIL PRESSURE SWITCH
TB2-6
TB2-7
FIRE ALARM N.C. CONTACTS
HOURMETER
OIL PRESS. GAUGE
WATER TEMP. GAUGE
VOLTMETER
OIL PRESS. SENDER
WATER TEMP. SENDER
TOLERANCES
WESTERBEKE CORPORATION
AVON MA. 02322
WIRING DIAGRAM, 8.0,10.0,11.0 BTD AND 12.5 BTDA-24V W/FIRE ALARM CONN
DIMENSIONS
SCALE NONE
E
41479